

# X-Tinguish® X-Treme Aerosol Fire Suppression Tool

R4.2020.1

## FOR USE IN CONTAINED SPACES



- **Locate** a safe area to deploy the X-Treme near the seat of the fire.
- **Locate** a clear and safe exit point.
- **Activating the X-Tinguish® X-Treme**
- 1.) Pull the R-pin (labeled #1) out of the unit. 2.) Pull the igniter pin out of the unit and immediately throw the unit into fire near the seat. It will deploy in 8 seconds. You must throw it before activation starts.
- **Close off enclosure** and allow the X-Tinguish® X-treme's aerosol to fully deploy and interact with the fire.
- **Evaluate fire conditions** and proceed according to Structure Fire Operational Guidelines.

The X-Tinguish® X-Treme has been tested and found to be effective on Class A, B, C and K fires in contained spaces.

User assumes all liability in connection with the use, misuse, handling or the mishandling of this device.

Do not use if not trained and familiar with instructions, MSDS and operational guidelines.

**Caution:** Thermal layers may be affected during deployment, resulting in hot air moving to the floor momentarily. Occupants should always be removed prior to deployment.

**Caution:** PPE (personal protective equipment) and (SCBA) self contained breathing apparatus should be used when entering an area in which the X-Tinguish® X-Treme has been deployed.

**Caution:** The X-Tinguish® X-Treme aerosol may reach high temperature during deployment. Maintain a deployment minimum safe distance of 2' (two feet) from another person.

**ALWAYS OVERHAUL FIRE  
AFTER DEPLOYMENT**



FLAME GUARD USA LLC.  
1000 BUTTERFIELD RD. SUITE 1029  
VERNON HILLS, IL 60061 USA  
INFO@FLAMEGUARDUSA.COM

Copyright © 2012-2020 Flame Guard USA

All Rights Reserved / X-Tinguish is a Trademark of Flame Guard USA,